



Crawford Sprinkler Company

OF SOUTH CAROLINA, INC.

Everything for Fire Protection

673 Lachicotte Rd.
Phone (803) 438-2994

FAX (803) 438-6065
Post Office Box 1267

LUGOFF, SOUTH CAROLINA 29078



DRY PIPE VALVE TEST

NAME OF PROPERTY: Waccamaw Center for Mental Health

ADDRESS 164 Waccamaw Medical Park Dr.

DATE: December 9, 2021

Conway

SC 29526

DRY PIPE VALVES

NO.	SIZE MAKE	MODEL YEAR	CONTROL SPRINKLERS IN	PRESS. (LB.) BEFORE TEST		CONTROL VALVE WIDE OPEN? IF NOT, HOW MANY TURNS?	OPERATED AT AIR PRESS. TIME (LB) (Min., Sec.)		OPERATION	REASON FOR FAILURE OR PARTLY	VALVE RESET	LIST REPAIRS	CONDITION		ALARMS OP.?
				AIR	WATER										
NO. 1	4" Central	AG 1995	Controls Ground Floor	AIR 44	WATER 64	YES	18	, 29	SATISFACTORY		YES	None	Interior of Body Water from Test Pipe Moving Parts Seals Rubber Facing	Good Yes Good Good Good	YES
NO. 2	4" Central	AG 1995	Second floor	AIR 45	WATER 58	YES	20	, 22	SATISFACTORY		YES	None	Interior of Body Water from Test Pipe Moving Parts Seals Rubber Facing	Good Yes Good Good Good	YES

QUICK OPENING DEVICES

NO.	MAKE	MODEL YEAR				OPERATION						
NO. 1	Central	A 1995				SATISFACTORY						
NO. 2	Central	A 1995				SATISFACTORY						

Thomas Ammons

Hill

Service Tech.
SIGNATURE AND TITLE OF PERSON MAKING TESTS

Danny Hill
WITNESS, OWNER OR LESSEE OF THE PROPERTY

Crawford Sprinkler Co.
COMPANY NAME AND ADDRESS
December 9, 2021
DATE OF EXAMINATION